

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE RULE - 18(2)

F O R M - (G)

NO. F&ES/FPW/S/157/115/23

Dated Guwahati the 03/06/23

To,

The Director,
Green Valley Public School,
Khanamukh, Jalukbari, Guwahati.

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND FIRE SAFETY MEASURES IN THE GREEN VALLEY PUBLIC SCHOOL AT KHANAMUKH, JALUKBARI, GUWAHATI.

With reference to your compliance report under No. NIL

dated **NIL** I hereby certified that the building as per description below at
Dag No **26** Patta No **28** Mouza **Jalukbari.**
(Place - **Khanamukh, Jalukbari, Guwahati**) has been inspected in respect of
implementation of inbuilt Fire Fighting, Fire Prevention and Fire Safety measures and is
declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No objection in
its occupation/ utilization for the purpose of **SCHOOL** subject to condition mentioned over
leaf.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR: - (Assam Type)

1. Floor area:- 1100 ft².

2. Purpose of utilization: -
For School Purpose.

MEZANINE/ BASEMENT FLOOR:-

1. Floor area:-

2. Purpose of utilization:-

FIRST FLOOR: -

1. Floor area: -

2. Purpose of utilization: -

SECOND FLOOR:-

1. Floor area:-

2. Purpose of utilization:-

THIRD FLOOR: -

1. Floor area:-

2. Purpose of utilization: -

FOURTH FLOOR

1. Floor area:-

2. Purpose of utilization:-

FIFTH FLOOR: -

1. Floor area: -

2. Purpose of utilization: -

SIXTH FLOOR:-

1. Floor area:-

2. Purpose of utilization:-

Contd... P. 
Principal
Green Valley Public School
West Jalukbari
Guwahati-14

SEVENTH FLOOR:-

1. Floor area: -
2. Purpose of utilization: ✓

EIGHT FLOOR:-


1. Floor area:-
2. Purpose of utilization: ✓

NINETH FLOOR:-

1. Floor area: -
2. Purpose of utilization: ✓

TENTH FLOOR:-

1. Floor area:-
2. Purpose of utilization: ✓



S.P. Cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

Dated Guwahati the _____

NO. F&ES/FPW/ _____


Copy to:-

1. The Deputy Commissioner, Kamrup (M), Assam for information and necessary action.
2. The Commissioner/ Chairman, G.M.C. Guwahati, Assam for information and necessary action.
3. The Station Officer, Pandu F&ES Station for information.


S.P. Cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - **31.03.2024**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted and its violation also punishable under Rule 17 & 19 of the Assam Fire Service Rules'1989.


S.P. Cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.


Principal
Green Valley Public School
West Jalukbari
Guwahati-14